

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YB202		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JOHNSON, BLAKE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 6882 E CO RD V						Town of OAKLAND						6882							
City SOUTH RANGE						State WI		Zip Code 54880				Street Address or Road Name and Number E CO RD V							
County Douglas		Co. Permit #		Notification # 7090749201		Completed 03-03-2018		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) KEITH R LIND				Lic. # 4684		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.54669 °N -91.94739 °W				Method Code GPS008					
Address KEITH LIND WELL DRLG INC MAPLE WI 54854				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 24 47 N 13 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)						
8.75 Surface 49			Yes Rotary - Mud Circulation No						- - S -		SAND		Surface 8						
6 49 120			Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						- - P G		HARDPAN & BOULDERS		8 46						
									K - B -		BLACK BASALT ROCK		46 120						
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		17.2 ft. below ground surface				24 in. above grade							
6		PLAIN END EXL ASTM A53B .280 18.97				Surface 49		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 39 ft. below surface Pumping at 12 GP M for 60 Hrs. Pumping Method ?				Disinfected ? Yes Capped ? Yes							
7. Grout or Other Sealing Material Method PUMPING														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NA					
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement															
BENTONITE & CUTTINGS		Surface 49																	
13. Constructor / Supervisory Driller						Lic #		Date Signed											
KL								03-03-2018											
Drill Rig Operator						Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		100

Comment:

Created On: 04-17-2018

Updated On: 06-25-2020

Review Status: