Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YB202

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNSON, BLAKE			Phone #
Mailing Address: 6882 E CO RD V			
City: SOUTH RANGE	State: WI	Zip Code: 54880	
County: Douglas	Co. Permit #:	Notification #: 7090749201	Completed: 03-03-2018

Well Constructor (Business Name): KEITH R LIND	Lic. #: 4684	Facility ID # (Public Wells):	
Address: KEITH LIND WELL DRLG INC MAPLE WI 54854		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6	

1. Well Location

Town of OAKLAND			Fire # (if avail.): 6882
Street Address or Road Name and Number: E CO RD V			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 46.54669 °N -91.94739 °W			Method Code: GPS008
NW NW or Govt Lot #	Section: 24	Township: 47 N	Range: 13 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	49
6	49	120

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	8
-	-	P	G	HARDPAN & BOULDERS	8	46
K	-	B	-	BLACK BASALT ROCK	46	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PLAIN END EXL ASTM A53B .280 18.97	Surface	49
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
17.2 ft. below ground surface

10. Pump Test
Pumping level 39 ft. below surface
Pumping at 12 GP M for 60 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PUMPING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE & CUTTINGS	Surface	49	S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
KL		03-03-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		100

Comment:

Created On: 04-17-2018 Updated On: 06-25-2020 Review Status: