

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YB203		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner COOK, EDWIN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 4484 S WIEHE DR						Village of POPLAR						4484							
City POPLAR						State WI		Zip Code 54864				Street Address or Road Name and Number							
S WIEHE DR						Subdivision Name				Lot #		Block #							
County Douglas		Co. Permit #		Notification # 7087187201		Completed 02-28-2018		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Well Constructor (Business Name) KEITH R LIND				Lic. # 4684		Facility ID # (Public Wells)				46.60147 °N -91.75183 °W		GPS008							
Address KEITH LIND WELL DRLG INC MAPLE WI 54854				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 33 48 N 11 W		2. Well Type Replacement				of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ?				OLD WELL							
3. Well serves 1 # of				Hicap Well ? No		Private, potable				Hicap Property ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		74		Yes Rotary - Mud Circulation		No		- - C -		CLAY		Surface		20			
6		74		240		No Rotary - Air		No		- - P G		HARDPAN & BOULDERS		20		70			
						No Rotary - Air & Foam		No		T - B -		BROWN BASALT ROCK		70		240			
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9.5 ft. below ground surface				24 in. above grade					
6		PLAINEND EXL ASTM A53B .280 18.97				Surface		74		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 70 ft. below surface				Disinfected ? Yes					
										Pumping at 7 GP M for 240 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				No			
Method PUMPING																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes					
BENTONITE & CUTTINGS				Surface		74		S		TO BE DONE									
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												KL						02-28-2018	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		98

Comment:

Created On: 04-17-2018

Updated On: 04-02-2019

Review Status: