Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YB367

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RUTH, CHAD			Phone #: (952)381-7144
Mailing Address: 5005 NATHAN LN			
City: PLYMOUTH	State: MN	Zip Code: 55442	
County: Burnett	Co. Permit #:	Notification #: 7034218801	Completed: 12-10-2017

1. Well Location

Town of MEENON

Fire # (if avail.): 6445

Street Address or Road Name and Number: CONNORS BRIDGE RD

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
DANIEL D HISCHER	175	

Address: KIRK HISCHER WELL DRILLING, LUCK WI 54853-9803

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Latitude / Longitude in Decimal Degree (DD): 45.8876 °N -92.31577 °W

Method Code: GPS008

NE	NW	Section	Township	Range
or Govt Lot #		11	39 N	16 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Hicap Permanent Well #	Common Well #	Specific Capacity
		2.5

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	5
4	5	48

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	G	C	ROCKS & CLAY, NC, BRN HARD	Surface	5
T	Q	G	G	ROCKS & GRAVEL, C, BRN HARD	5	30
T	Q	G	-	GRAVEL, C, BRN, HARD	30	48

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL 11 #-FT A53 .237 X 4.5 X 18 FT IPSCO USA T&C	Surface	44
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	V SDLOT S. STEEL .012	43	48

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 15 GP M for 0.05 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method SHOVEL

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL CUTTINGS	Surface	5	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NO OTHER WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
DH		12-19-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DH		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Overhang		2
Shoreline/Pool		150
Sewer - Building Sanitary		27
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-09-2018 Updated On: 01-09-2018 Review Status: