

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YB367		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner RUTH, CHAD						Phone # (952)381-7144		1. Well Location				Fire # (if avail.)											
Mailing Address 5005 NATHAN LN						Town of MEENON						6445											
City PLYMOUTH						State MN		Zip Code 55442				Street Address or Road Name and Number CONNORS BRIDGE RD											
County Burnett		Co. Permit #		Notification # 7034218801		Completed 12-10-2017		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) DANIEL D HISCHER				Lic. # 175		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8876 °N -92.31577 °W				Method Code GPS008									
Address KIRK HISCHER WELL DRILLING LUCK WI 54853-9803				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 11 39 N 16 W				2. Well Type New Well													
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in													
Hicap Permanent Well #		Common Well #		Specific Capacity 2.5		Reason for replaced or reconstructed well ?				Construction Type Drilled													
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No				Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE												5. Drillhole Dimensions and Construction Method		8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		5		Rotary - Mud Circulation				Rotary - Air				T V G C ROCKS & CLAY, NC, BRN HARD				Surface		5			
4		5		48		Rotary - Air & Foam				Drill-Through Casing Hammer				T Q G G ROCKS & GRAVEL, C, BRN HARD				5		30			
						Reverse Rotary				Cable-tool Bit ___ in. dia...				T Q G - GRAVEL, C, BRN, HARD				30		48			
						Dual Rotary																	
						Temp. Outer Casing ___ in. dia																	
						Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		24 ft. below ground surface				15 in. above grade									
4		STEEL 11 #-FT A53 .237 X 4.5 X 18 FT IPSCO USA T&C				Surface		44		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 30 ft. below surface				Disinfected ? Yes									
4		V SDLOT S. STEEL .012				43		48		Pumping at 15 GP M for 0.05 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				13. Constructor / Supervisory Driller							
Method SHOVEL																Lic #				Date Signed			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No											
DRILL CUTTINGS		Surface		5		S		NO OTHER WELL															
												DH				12-19-2017							
												Drill Rig Operator				Lic or Reg #				Date Signed			
												DH											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Shoreline/Pool		150
Building Overhang		2	Sewer - Building Sanitary		27
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-09-2018

Updated On: 01-09-2018

Review Status: