

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YB789		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner QUIMBY, RAYMOND						Phone # (408)662-8004		1. Well Location				Fire # (if avail.) 980	
Mailing Address 978 ST RD 13						Town of BIG FLATS						Street Address or Road Name and Number 980 ST RD 13	
City BIG FLATS			State WI		Zip Code 54613		Subdivision Name				Lot # Block #		
County Adams		Co. Permit #		Notification # 7079191601		Completed 01-30-2018		Latitude / Longitude in Decimal Degree (DD) 44.11453 °N -89.8066 °W				Method Code GPS008	
Well Constructor (Business Name) RODNEY J REICHHOFF				Lic. # 7202		Facility ID # (Public Wells)				SW SE Section Township Range or Govt Lot # 17 19 N 6 E			
Address W8740 EVERGREEN DR OXFORD WI 53952				Well Plan Approval #		2. Well Type Replacement of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Reason for replaced or reconstructed well ? PLUGGED DRIVEN 1 1/4 POINT							
Specific Capacity 0.6				Approval Date (mm-dd-yyyy)		Construction Type Driven Point							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
2 Surface 63			Rotary - Mud Circulation										
1.25 63 66			Rotary - Air										
			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Yes Cable-tool Bit 1.25in. dia... No										
			Dual Rotary										
			Temp. Outer Casing ___ in. dia										
			Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
Y - S -			YELLOW SAND						Surface 30				
R - C -			RED CLAY						30 45				
- - Y -			SAND & GRAVEL						45 66				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)							
2		WHEATLAND ERW ASTM A53 3.75 LBS COUPLED				Surface 63							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)							
1.25		STAINLESS STEEL 80 GA				63 66							
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.) To (ft.) # Sacks Cement									
Surface													
9. Static Water Level													
13 ft. below ground surface													
10. Pump Test													
Pumping level 30 ft. below surface													
Pumping at 10 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
14 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
RR				01-30-2018									
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		3
			Septic or Holding, or POWTS Tank		34

Comment:

Created On: 02-19-2018

Updated On: 05-04-2020

Review Status: