Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YB789

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: QUIMBY, RAYMOND			Phone #: (408)662-8004
Mailing Address: 978 ST RD 13			
City: BIG FLATS	State: WI	Zip Code: 54613	
County: Adams	Co. Permit #:	Notification #: 7079191601	Completed: 01-30-2018

Well Constructor (Business Name): RODNEY J REICHHOFF	Lic. #: 7202	Facility ID # (Public Wells):
Address: W8740 EVERGREEN DR OXFORD WI 53952		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6

1. Well Location

Fire # (if avail.): 980

Town of BIG FLATS

Street Address or Road Name and Number: 980 ST RD 13

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.11453 °N -89.8066 °W				Method Code: GPS008
SW SE or Govt Lot #	Section: 17	Township: 19 N	Range: 6 E	

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: PLUGGED DRIVEN 1 1/4 POINT

Construction Type: Driven Point

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	63
1.25	63	66

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 1.25in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	S	-	YELLOW SAND	Surface	30
R	-	C	-	RED CLAY	30	45
-	-	Y	-	SAND & GRAVEL	45	66

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND ERW ASTM A53 3.75 LBS COUPLED	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	STAINLESS STEEL 80 GA	63	66

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		01-30-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65

Type	Qualifier	Distance
Building Overhang		3
Septic or Holding, or POWTS Tank		34

Comment:

Created On: 02-19-2018 Updated On: 05-04-2020 Review Status: