Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YB790

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SUNAERLAGE, DOUG	Phone #: (608)547-2797
Mailing Address: 2845 11TH DR	
City: EASTON	State: WI — Zip Code: 53910
County: Adams	Co. Permit #:
Notification #: 7085483401	Completed: 02-14-2018
Well Constructor (Business Name): RODNEY J REICHHOFF	Lic. #: 7202
Facility ID # (Public Wells):	
Address: W8740 EVERGREEN DR OXFORD WI 53952	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

1. Well Location

Town of EASTON	Fire # (if avail.): 2845
Street Address or Road Name and Number: 2845 11TH DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.8409 °N -89.80757 °W	Method Code: GPS008
SE NW or Govt Lot #:	Section: 29 — Township: 16 N — Range: 6 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: PLUGGED DRIVEN POINT

Construction Type: Jetted

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	90
1.25	90	93

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 1.25in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	C	-	RED CLAY	Surface	18
-	N	S	-	FINE PACKY SAND	18	25
R	-	C	-	RED CLAY	25	60
-	N	S	-	FINE PACKY SAND	60	80
-	-	Y	-	SAND & GRAVEL	80	93

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND ERW ASTM A53 3.75 LBS COUPLED	Surface	90
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	STAINLESS STEEL 80 GA	90	93

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

30 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	26	1.5 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		02-20-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		76

Type	Qualifier	Distance
Building Overhang		8
Septic or Holding, or POWTS Tank		46

Comment:

Created On: 03-07-2018 Updated On: 05-04-2020 Review Status: