

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YB791		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BEAVER, TOM						Phone # (920)268-7861											
Mailing Address W2442 VALLEYWOOD LN						1. Well Location						Fire # (if avail.)					
City APPLETON						State WI		Zip Code 54915				Town of PACKWAUKEE		W5075			
County Marquette						Co. Permit #		Notification # 7089997501				Completed 02-27-2018		Street Address or Road Name and Number W5075 CO RD K			
Well Constructor (Business Name) RODNEY J REICHHOFF						Lic. # 7202		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.77037 °N -89.4145 °W				Method Code GPS008	
Address W8740 EVERGREEN DR OXFORD WI 53952						Well Plan Approval #				NW NE		Section 22		Township 15 N		Range 9 E	
Hicap Permanent Well #						Common Well #		Specific Capacity 0.8				2. Well Type Replacement of previous unique well # constructed in					
3. Well serves 1 # of Private, potable						Hicap Well ? No				Reason for replaced or reconstructed well ? PLUGGED DRIVEN POINT							
Heat Exchange ___ # of drillholes						Hicap Property ? No				Construction Type Driven Point							
Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock														
2 Surface 42			Rotary - Mud Circulation														
1.25 42 45			Rotary - Air														
			Rotary - Air & Foam														
			Drill-Through Casing Hammer														
			Reverse Rotary														
			Cable-tool Bit ___ in. dia...														
			Dual Rotary														
			Temp. Outer Casing ___ in. dia														
			Removed? ___ depth ft. (If NO explain on back side)														
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
Y N S -				FINE YELLOW SAND				Surface		20							
- - Y -				SAND & GRAVEL				20		45							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
2		WHEATLAND ERCEL ASTM-A53 COUPLED 3.75 LBS				Surface		42									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
1.25		STAINLESS STEEL 80 GA				42		45									
7. Grout or Other Sealing Material										9. Static Water Level							
Method										24 ft. below ground surface							
Kind of Sealing Material										11. Well Is							
From (ft.) To (ft.) # Sacks Cement										20 in. above grade							
Surface										Developed ? Yes							
										Disinfected ? Yes							
										Capped ? Yes							
12. Notified Owner of need to fill & seal ?										Filled & Sealed Well(s) as needed? Yes							
13. Constructor / Supervisory Driller										Lic #		Date Signed					
RR												02-28-2018					
Drill Rig Operator										Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Septic or Holding, or POWTS Tank		86

Comment:

Created On: 03-27-2018

Updated On: 04-08-2020

Review Status: