Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YD144

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOURASSA, DAN			Phone #: (715)372-8964
Mailing Address: 70615 CO RD A			
City: IRON RIVER	State: WI	Zip Code: 54847	
County: Bayfield	Co. Permit #:	Notification #: 6950062101	Completed: 09-29-2017

Well Constructor (Business Name): MATT H LONG	Lic. #: 145	Facility ID # (Public Wells):	
Address: LONG'S WELL DRILLING POPLAR WI 54864-0355		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of TRIPP

Fire # (if avail.): 70385

Street Address or Road Name and Number: CO RD A

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
46.5968 °N	-91.4091 °W			GPS008

SE	NE	Section	Township	Range
or Govt Lot #		31	48 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6.5	Surface	80
4	80	84

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	63
-	-	S	U	DIRTY SAND	63	70
-	-	Y	-	SAND/GRAVEL	70	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	EXLTUBE A53B SCHD40 WELDED JOINTS	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	STAINLESS STEEL 10 SLOT	80	84

7. Grout or Other Sealing Material

Method DRILLING MUD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
QUICK GEL	Surface	80	4 S

9. Static Water Level
6 ft. above ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 8 GP M for 6 Hrs.
Pumping Method ?

11. Well Is
28 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
MHL		10-02-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: BLDG OVERHANG, SEPTIC/SEWER, BLDG SEWER NOT IN

Created On: 11-02-2017 Updated On: 06-25-2020 Review Status: