Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YD145

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANDERSON, ERIC	Phone #: (715)969-8763
Mailing Address: 11529 S LAKE BLVD	
City: LAKE NEBAGAMON	State: WI — Zip Code: 54849
County: Douglas	Co. Permit #:
Notification #: 6968652301	Completed: 10-06-2017
Well Constructor (Business Name): MATT H LONG	Lic. #: 145
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: LONG'S WELL DRILLING, POPLAR WI 54864-0355	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Village of LAKE NEBAGAMON	Fire # (if avail.): 11529
Street Address or Road Name and Number: LAKE BLVD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.4921 °N -91.7012 °W	Method Code: GPS008

SE	SE	Section	Township	Range
or Govt Lot #		2	46 N	11 W

2. Well Type Replacement

of previous unique well #: — constructed in: 1986

Reason for replaced or reconstructed well ?: OLD WELL NOT USEABLE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6.5	Surface	135
4	135	139

Upper Enlarged Drillhole: Yes

Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	M	DIRTY SAND/SILT	Surface	53
-	-	Y	-	SAND/GRAVEL	53	58
-	-	S	M	DIRTY SAND/SILT	58	70
-	-	P	G	HARDPAN/BOULDERS	70	130
-	A	S	-	COARSE SAND	130	139

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	EXLTUBE A53B SCHD40 WELDED JOINTS	Surface	135
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL 10 SLOT	135	139

7. Grout or Other Sealing Material

Method: DRILLING MUD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
QUIK GEL	Surface	135	5 S

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP M for 48 Hrs.

Pumping Method ?

11. Well Is

26 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

TO BE DONE LATER

13. Constructor / Supervisory Driller	Lic #	Date Signed
MHL		10-09-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		50	Shoreline/Pool		180

Comment: BLDG OVERHANG, SEPTIC/SEWER, BLDG SEWER NOT IN

Created On: 11-02-2017 Updated On: 06-25-2020 Review Status: