Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YD193

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BODEN, RAYMOND			Phone #
Mailing Address: PO BOX 12800			
City: GREEN BAY	State: WI	Zip Code: 54307	
County: Door	Co. Permit #:	Notification #: 6989629401	Completed: 03-21-2018

1. Well Location

Fire # (if avail.): 7909

Town of EGG HARBOR

Street Address or Road Name and Number: 7909 HWY 42

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): MARK E EUCLIDE	Lic. #: 5905	Facility ID # (Public Wells)	
Address: EUCLIDE WELL DRILLING INC STURGEON BAY WI 54235		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.9	

Latitude / Longitude in Decimal Degree (DD): 45.0551 °N -87.2809 °W

Method Code: GPS008

SE	SE	Section	Township	Range
or Govt Lot #		24	30 N	26 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: BELOW GRADE IN HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	170
6	170	202

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - L -	LIMESTONE	Surface	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P.E. WT. 18.97 ASTMA55B IPSCO (WELDED JOINT)	Surface	172
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

140 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 35 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	170	68 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

OTHERS FILLED IN OLD WELL.

13. Constructor / Supervisory Driller	Lic #	Date Signed
ME		03-21-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Drain - Sanitary		25

Comment:

Created On: 04-17-2018 Updated On: 12-03-2019 Review Status: