

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YD193		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BODEN, RAYMOND					Phone #		1. Well Location Fire # (if avail.) Town of EGG HARBOR 7909 Street Address or Road Name and Number 7909 HWY 42												
Mailing Address PO BOX 12800																			
City GREEN BAY			State WI		Zip Code 54307		Subdivision Name Lot # Block #												
County		Co. Permit #		Notification #		Completed													
Door				6989629401		03-21-2018													
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code								
MARK E EUCLIDE				5905				45.0551 °N -87.2809 °W			GPS008								
Address EUCLIDE WELL DRILLING INC STURGEON BAY WI 54235				Well Plan Approval #		SE SE		Section		Township		Range							
				Approval Date (mm-dd-yyyy)		or Govt Lot #		24		30 N		26 E							
Hicap Permanent Well #			Common Well #		Specific Capacity		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? BELOW GRADE IN HOME Construction Type Drilled												
					0.9														
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		170		No Rotary - Mud Circulation		No		- - L -		LIMESTONE		Surface		202			
6		170		202		Yes Rotary - Air		Yes											
						No Rotary - Air & Foam		No											
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												8. Geology							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		140 ft. below ground surface				11. Well Is 16 in. above grade					
6		NEW BLACK STEEL P.E. WT. 18.97 ASTMA55B IPSCO (WELDED JOINT)				Surface		172		10. Pump Test Pumping level 180 ft. below surface Pumping at 35 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method BRADENHEAD												9. Static Water Level				11. Well Is			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No									
CEMENT				Surface		170		68 S		Filled & Sealed Well(s) as needed? Yes OTHERS FILLED IN OLD WELL.									
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												ME						03-21-2018	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Drain - Sanitary		25

Comment:

Created On: 04-17-2018

Updated On: 12-03-2019

Review Status: