Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YE016

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: WONDRA, SCOTT	Phone #: (715)349-5993
Mailing Address: 8101 TEWALT RD	
City: SIREN	State: WI — Zip Code: 54872
County: Burnett	Co. Permit #:
Notification #: 6979693901	Completed: 10-20-2017
Well Constructor (Business Name): BRANT C BEECROFT	Lic. #: 7298
Facility ID # (Public Wells):	
Address: DAN WELL CO FREDERIC WI 54837	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.6	

1. Well Location

Town of SIREN				Fire # (if avail.):
Street Address or Road Name and Number: 8101 TEWALT RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.76203 °N -92.40482 °W				Method Code: GPS008
NE SW or Govt Lot #:	Section: 19	Township: 38 N	Range: 16 W	

2. Well Type Replacement
of previous unique well #: constructed in:
Reason for replaced or reconstructed well ?: OLD 4 INCH WELL OWNER WANTED REPLACED
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ?
Hicap Property ?
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	250

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Yes Dual Rotary ..... No
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	S	-	NON-CAVING SAND	Surface	135
-	V	X	M	NON-CAVING SAND, SILT, CLAY	135	170
-	-	P	-	HARDPAN	170	235
-	-	Y	U	DIRTY SAND, FINE GRAVEL	235	243
-	A	G	S	COURSE GRAVEL, SAND	243	250

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	WHEATLAND ASTM-A53-B PLN. END-BT. WLD.	Surface	242
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	ALLOY S.S. #10 #12	242	250

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULATED BENTONITE	Surface	250	5 S

9. Static Water Level
95 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BB		10-23-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		72
Privy		54

Type	Qualifier	Distance
Ditch or Culvert		195
Animal Yard - Include Hutches		57
Septic or Holding, or POWTS Tank		81

Comment:

Created On: 12-21-2017 Updated On: 06-30-2020 Review Status: