

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YE020		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner NORTHSTAR BISON						Phone # (715)497-5673		1. Well Location				Fire # (if avail.)			
Mailing Address 1936 28TH AVE						Town of OAK GROVE									
City RICE LAKE						State WI		Zip Code 54868							
County Barron		Co. Permit #		Notification # 6989762001		Completed 11-02-2017		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) BRANT C BEECROFT				Lic. # 7298		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.62155 °N -91.72842 °W				Method Code GPS008	
Address DAN WELL CO FREDERIC WI 54837				Well Plan Approval #		SW NE		Section 9		Township 36 N		Range 11 W			
						or Govt Lot #									
Address DAN WELL CO FREDERIC WI 54837				Approval Date (mm-dd-yyyy)		2. Well Type New Well									
Hicap Permanent Well #				Common Well #		Specific Capacity 1.7		of previous unique well # constructed in							
3. Well serves 1 # of WATER ANIMALS				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		69											
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Yes Dual Rotary No Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
T - Z S		TAN SANDY GRAVELY CLAY		Surface		6									
- A G S		SAND, COARSE GRAVEL, ROCKS		6		40									
- - X -		SAND, CLAY		40		53									
- - G -		BOULDER		53		59									
- A G G		COARSE GRAVEL, BOULDERS		59		62									
- A G C		COARSE GRAVEL, ROCKS, CLAY		62		65									
- A G S		COARSE GRAVEL, ROCKS, SAND		65		69									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification		From (ft.)		To (ft.)									
6		WHEATLAND ASTM-A53B-PLN. END. BT. WLD.		Surface		66									
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)									
4		JOHNSON S.S. #15		66		69									
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
		Surface													
9. Static Water Level															
40 ft. below ground surface															
10. Pump Test															
Pumping level 55 ft. below surface															
Pumping at 25 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
16 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?												No			
NONE															
13. Constructor / Supervisory Driller															
BB												Date Signed 11-15-2017			
Drill Rig Operator												Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Ditch or Culvert		50

Comment:

Created On: 12-21-2017

Updated On: 12-21-2017

Review Status: