

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YE058		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KAZLAUSKY, SHANE						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 1296 OLD HWY 51						Town of ARBOR VITAE						1296			
City ARBOR VITAE						State WI		Zip Code 54568				Street Address or Road Name and Number OLD HWY 51			
County Vilas		Co. Permit #		Notification # 8949047301		Completed 11-05-2022		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) MERCER WELL C.M.				Lic. # 8178		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.91354 °N -89.67357 °W				Method Code SCR002	
Address PO BOX 718 2809 CEMETARY ROAD LAC DU FLAMBEAU WI 54538				Well Plan Approval #		SW SW		Section 30		Township 40 N		Range 7 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 7.5		2. Well Type Replacement of previous unique well # constructed in									
3. Well serves 1 # of HOME Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No		Reason for replaced or reconstructed well ? 2" DRIED UP Construction Type Drilled									
				Hicap Property ? No											
				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 40		Upper Enlarged Drillhole				Lower Open Bedrock					
						No Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						Yes Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ____ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ____ in. dia									
						No Removed? ____ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes						Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
X						X-SAND & CLAY				Surface		40			
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 37		11. Well Is 14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.) 5		Screen type, material & slot size				From (ft.) 37		To (ft.) 40							
		JOHNSON 12 SLOT													
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE		Surface		1		0.25 S									
9. Static Water Level 15 ft. below ground surface															
10. Pump Test Pumping level 17 ft. below surface Pumping at 15 GP M for 4 Hrs. Pumping Method ? Test Pump															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
FS				4207		10-05-2024									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	=	40	POWTS dispersal component (soil absorption unit or mound)	=	55

Comment:

Created On: 12-06-2024

Updated On: 12-09-2024

Review Status: APPROVED