Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YE060

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: GOLONKA, JIM	Phone #
Mailing Address: 2460 W HORNER RD	
City: MERCER	State: WI — Zip Code: 54547
County: Iron	Co. Permit #: — Notification #: 9274878401 — Completed: 10-14-2023
Well Constructor (Business Name): MERCER WELL C.M.	Lic. #: 8178 — Facility ID # (Public Wells):
Address: PO BOX 718 2809 CEMETARY ROAD LAC DU FLAMBEAU WI 54538	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.4	

1. Well Location

Town of MERCER	Fire # (if avail.): 2460W
Street Address or Road Name and Number: HOERNERS DR	
Subdivision Name: — Lot #: — Block #:	
Latitude / Longitude in Decimal Degree (DD): 46.18153 °N -90.05121 °W	Method Code: SCR002
NW NW or Govt Lot #: — Section: 30 — Township: 43 N — Range: 4 E	

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: 1.25" DRIED UP
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	78

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	20
		X		X-SAND & CLAY	20	28
		C		C-CLAY	28	50
		Z		Z-CLAY & GRAVEL	50	70
	N	Y		N-FINE Y-SAND & GRAVEL	70	78

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM A53 WELDED 18.97LBS WHEATLAND	Surface	75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	JOHNSON 10	75	78

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 47 ft. below surface
Pumping at 15 GP M for 8 Hrs.
Pumping Method ? Test Pump

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	1	0.25 S

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
FS	4207	10-05-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	40	POWTS dispersal component (soil absorption unit or mound)	>	55

Comment: 1.25" PT WAS ONMLY 15' DEEP. PULLED IT OUT WITH BACKHOE AND FILLED HOLE WITH GRANULAR BENTONITE (3/4 SACK)

Created On: 12-06-2024 Updated On: 12-09-2024 Review Status: APPROVED