

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YE072		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner STECHSCHULTE, BECKY						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address S68 W29325 VALLEY WOOD PASS						Town of BARNES															
City MUKWONAGO						State WI		Zip Code 53149				Street Address or Road Name and Number 55285 LITTLE ISLAND RD									
County Bayfield		Co. Permit #		Notification # 7033819201		Completed 11-28-2017		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) PAUL R ANDERSON				Lic. # 4681		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.3787 °N -91.5206 °W											
Address PAUL R ANDERSON WELL DRILLING ASHLAND WI 54806				Well Plan Approval #		NW SE		Section 17		Township 45 N		Method Code GCD013									
				Approval Date (mm-dd-yyyy)		Range 9 W															
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type New Well				of previous unique well # constructed in											
3. Well serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?															
Heat Exchange ___ # of drillholes				Hicap Property ? No		Hicap Potable ?				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		6		Rotary - Mud Circulation						- - S -		DRY SAND		Surface		40			
4		6		60		Rotary - Air						- W S -		WET SAND		40		57			
						Rotary - Air & Foam						- W S -		WATER & SAND		57		60			
						Drill-Through Casing Hammer															
						Reverse Rotary															
						Yes Cable-tool Bit ___ in. dia...				No											
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				16 in. above grade							
4.5		OD 4IN ID T&C ASTM A-53-B IPSCO				Surface		60		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 50 ft. below surface				Disinfected ? Yes							
2		10 SLOT SCREEN 4/2 KPAC				57		60		Pumping at 10 GP M for 2 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?											
CASING SEAL				Surface		6		S		N/A											
13. Constructor / Supervisory Driller								Lic #		Date Signed											
PA										11-28-2017											
Drill Rig Operator								Lic or Reg #		Date Signed											
BH										11-28-2017											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		50
			Septic or Holding, or POWTS Tank		90

Comment:

Created On: 02-19-2018

Updated On: 06-25-2020

Review Status: