Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YE076

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PRIBYL, LARRY	Phone #: (651)500-1213
Mailing Address: 44925 BEAR POINT RD	
City: CABLE	State: WI — Zip Code: 54821

County	Co. Permit #	Notification #	Completed
Bayfield		6943025301	03-06-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
PAUL R ANDERSON	4681	

Address: PAUL R ANDERSON WELL DRILLING, ASHLAND WI 54806

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Fire # (if avail.): 44925

Town of NAMAKAGON

Street Address or Road Name and Number: BEAR POINT RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
46.22708 °N -91.11528 °W	GPS008

NE NE or Govt Lot #	Section	Township	Range
	9	43 N	6 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	6
4	6	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	DRY SAND	Surface	12
-	W	S	-	WET SAND	12	37
-	W	S	-	WATER & SAND	37	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4.5	OD 4IN ID T&C ASTM A-53-B IPSCO	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	10 SLOT SCREEN 4/2 K PAC	37	40

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CASING SEAL	Surface	6	S

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
PRA		03-06-2018
Drill Rig Operator	Lic or Reg #	Date Signed
BH		03-06-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		30	Shoreline/Pool		120

Comment: NO SEPTIC AT THE TIME

Created On: 04-17-2018 Updated On: 06-25-2020 Review Status: