Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YF659

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: WELLNITZ, PHIL	Phone #: (608)290-4466
Mailing Address: 14824 W LANG RD	
City: ORFORDVILLE	State: WI — Zip Code: 53576
County: Rock	Co. Permit #:
Notification #: 41547070	Completed: 08-31-2011
Well Constructor (Business Name): GOVERT WELL & PUMP INC	Lic. #: 658
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 5234 N CO RD F JANESVILLE WI 53545	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.6	

1. Well Location

Town of ORFORDVILLE	Fire # (if avail.): 14824
Street Address or Road Name and Number: 14824 W LANG RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.647 °N -89.2944 °W	Method Code: GCD013
SW SE or Govt Lot #:	Section: 10 — Township: 2 N — Range: 10 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOMES

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	C	Sand & Gravel, Clayey	Surface	42
-	-	X	-	Sand & Clay	42	56
T	-	N	-	Tan/Brown, Sandstone	56	65
R	-	N	-	Red, Sandstone	65	69
I	-	N	-	White, Sandstone	69	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	TMK IPSCO ASTM A53 ASME 6.625 .280 SCD40 NEW WELDED ENDS	Surface	56
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 30 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Granular bentonite	Surface	56	3

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

OLD WELL STILL IN USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
M.G.		09-01-2011
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
A.B.		09-01-2011

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 09-12-2011 Updated On: 12-09-2019 Review Status: APPROVED