

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YF659		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner WELLNITZ, PHIL						Phone # (608)290-4466		1. Well Location				Fire # (if avail.)		
Mailing Address 14824 W LANG RD						Town of ORFORDVILLE						14824		
City ORFORDVILLE						State WI		Zip Code 53576				Street Address or Road Name and Number 14824 W LANG RD		
County Rock		Co. Permit #		Notification # 41547070		Completed 08-31-2011		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) GOVERT WELL & PUMP INC				Lic. # 658		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.647 °N -89.2944 °W			Method Code GCD013	
Address 5234 N CO RD F JANESVILLE WI 53545				Well Plan Approval #		SW SE		Section 10		Township 2 N		Range 10 E		
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6				2. Well Type New Well				
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?				
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled				of previous unique well # constructed in				
3. Well serves 1 # of HOMES														
Private, potable														
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		100		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>Yes</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
-	-	Y	C	Sand & Gravel, Clayey				Surface		42				
-	-	X	-	Sand & Clay				42		56				
T	-	N	-	Tan/Brown, Sandstone				56		65				
R	-	N	-	Red, Sandstone				65		69				
I	-	N	-	White, Sandstone				69		100				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		TMK IPSCO ASTM A53 ASME 6.625 .280 SCD40 NEW WELDED ENDS				Surface		56						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
Granular bentonite				Surface		56		3						
9. Static Water Level														
30 ft. below ground surface														
10. Pump Test														
Pumping level 80 ft. below surface														
Pumping at 30 GP M for 2 Hrs.														
Pumping Method ?														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? No														
OLD WELL STILL IN USE														
13. Constructor / Supervisory Driller								Lic #		Date Signed				
M.G.										09-01-2011				
Drill Rig Operator								Lic or Reg #		Date Signed				
A.B.										09-01-2011				

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 09-12-2011

Updated On: 12-09-2019

Review Status: APPROVED