

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YG937		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KABAT, DAVID						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 1068 GOLFVIEW DRIVE						Town of SEVASTOPOL						5425							
City BRILLION						State WI		Zip Code 54110				Street Address or Road Name and Number							
E SYLVAN VIEW CIRCLE						Subdivision Name				Lot #		Block #							
County		Co. Permit #		Notification #		Completed		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Door		49586751		10-22-2013		44.9323 °N -87.2208 °W				GCD013									
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		SW NE Section Township Range		or Govt Lot #		4 28 N 27 E							
JORNS HARVEY & DAVID WELL DRLG INC				68		Well Plan Approval #		2. Well Type New Well											
Address 5235 BLUFF CT STURGEON BAY WI 54235-9790				Approval Date (mm-dd-yyyy)		of previous unique well # constructed in													
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?													
				0.2															
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled													
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		23		<u>No</u> Rotary - Mud Circulation		<u>No</u>		- - C -		Clay		Surface		17			
8		23		171		<u>Yes</u> Rotary - Air		<u>Yes</u>		- - P -		Hardpan		17		23			
6		171		281		<u>No</u> Rotary - Air & Foam		<u>No</u>		- - L -		Limestone/Dolomite		23		281			
						<u>No</u> Drill-Through Casing Hammer													
						Reverse Rotary													
						<u>No</u> Cable-tool Bit ___ in. dia...		<u>No</u>											
						<u>No</u> Dual Rotary		<u>No</u>											
						<u>Yes</u> Temp. Outer Casing 8in. dia													
						<u>Yes</u> Removed? 23depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												8. Geology							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is					
6		STANDARD WEIGHT BLACK STEEL CASING. NEW PLAIN END. ASTM-A53 WT. PER FT. 18.97 WHEATLAND TUBE.				Surface		171		52 ft. below ground surface				12 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes					
										Pumping level 185 ft. below surface				Disinfected ? Yes					
										Pumping at 20 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method Bradenhead												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
Neat cement grout		Surface		171		35 S													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												H.J.						10-23-2013	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Building Overhang		15
			Septic or Holding, or POWTS Tank		65

Comment:

Created On: 12-19-2013

Updated On: 12-03-2019

Review Status: APPROVED