Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: YG937

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KABAT, DAVID	Phone #
Mailing Address: 1068 GOLFVIEW DRIVE	
City: BRILLION	State: WI — Zip Code: 54110
County: Door	Co. Permit #: — Notification #: 49586751 — Completed: 10-22-2013
Well Constructor (Business Name): JORNS HARVEY & DAVID WELL DRLG INC	Lic. #: 68 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Address: 5235 BLUFF CT, STURGEON BAY WI 54235-9790	
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.2	

1. Well Location

Town of SEVASTOPOL	Fire # (if avail.): 5425
Street Address or Road Name and Number: E SYLVAN VIEW CIRCLE	
Subdivision Name: — Lot #: — Block #: —	
Latitude / Longitude in Decimal Degree (DD): 44.9323 °N -87.2208 °W	Method Code: GCD013
SW NE or Govt Lot #: — Section: 4 — Township: 28 N — Range: 27 E	

2. Well Type New Well
of previous unique well # — constructed in —
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	23
8	23	171
6	171	281

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 23depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	Clay	Surface	17
-	-	P	-	Hardpan	17	23
-	-	L	-	Limestone/Dolomite	23	281

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD WEIGHT BLACK STEEL CASING. NEW PLAIN END. ASTM-A53 WT. PER FT. 18.97 WHEATLAND TUBE.	Surface	171
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: Bradenhead

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement grout	Surface	171	35 S

9. Static Water Level
52 ft. below ground surface

10. Pump Test
Pumping level 185 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
H.J.		10-23-2013
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Building Overhang		15
			Septic or Holding, or POWTS Tank		65

Comment:

Created On: 12-19-2013 Updated On: 12-03-2019 Review Status: APPROVED