Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: YG939

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	HOFFMAN, LEON
Phone #	
Mailing Address	2361 OMRO ROAD
City	OSHKOSH
State	WI
Zip Code	54904

County	Co. Permit #	Notification #	Completed
Door		49769718	11-15-2013

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
JORNS HARVEY & DAVID WELL DRLG INC	68	

Address: 5235 BLUFF CT
STURGEON BAY WI 54235-9790

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of BAILEYS HARBOR

Fire # (if avail.): 7399

Street Address or Road Name and Number: HWY 57

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.03075	°N	-87.1484	°W	GPS007

	Section	Township	Range
or Govt Lot # 3	31	30 N	28 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
8	6	171
6	171	281

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 7depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	P	-	Hardpan	Surface	3
-	-	L	-	Limestone/Dolomite	3	281

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD WEIGHT BLACK STEEL CASING. NEW PLAIN END. ASTM-53 WT. PER FT. 18.97 WHEATLAND TUBE	Surface	171
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method Bradenhead

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement grout	Surface	171	50 S

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 175 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
SHARED WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
H.J.		11-16-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 12-19-2013 Updated On: 12-19-2013 Review Status: APPROVED