

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YG940		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner LACART, JOHN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 11321 BEACH ROAD						Town of LIBERTY GROVE						11321							
City SISTER BAY						State WI		Zip Code 54234				Street Address or Road Name and Number BEACH ROAD							
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #					
Door				49855579		11-19-2013													
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code					
JORNS HARVEY & DAVID WELL DRLG INC				68						45.21957 °N -87.12178 °W				GPS007					
Address 5235 BLUFF CT STURGEON BAY WI 54235-9790				Well Plan Approval #				NW SE		Section		Township		Range					
				Approval Date (mm-dd-yyyy)				or Govt Lot # 3		29		32 N		28 E					
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
						0.2													
3. Well serves 1 # of HOME						Hicap Well ? No													
Private, potable						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		6		No Rotary - Mud Circulation				No		- - P -		Hardpan		Surface		3	
8		6		171		Yes Rotary - Air				Yes		- - L -		Limestone/Dolomite		3		241	
6		171		241		No Rotary - Air & Foam				No									
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...				No									
						No Dual Rotary				No									
						Yes Temp. Outer Casing 8in. dia													
						Yes Removed? 7depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		39 ft. below ground surface				12 in. above grade					
6		STANDARD WEIGHT BLACK STEEL CASING. NEW PLAIN END. ASTM-A53 WT. PER FT. 18.97 WHEATLAND TUBE.				Surface		171		10. Pump Test				Developed ? Yes					
										Pumping level 175 ft. below surface				Disinfected ? Yes					
										Pumping at 25 GP M for 1 Hrs.				Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method Bradenhead												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
Neat cement grout & bentonite				Surface		171		93 S											
13. Constructor / Supervisory Driller								Lic #		Date Signed									
H.J.										11-20-2013									
Drill Rig Operator								Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Septic or Holding, or POWTS Tank		125

Comment:

Created On: 12-19-2013

Updated On: 12-03-2019

Review Status: APPROVED