

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YJ366		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BARLOW, KENT						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 2641 N 82ND ST						Town of SPRINGWATER						W5680					
City WAUWATOSA						State WI		Zip Code 53213				Street Address or Road Name and Number					
County Waushara						Co. Permit #		Notification # 49213501		Completed 09-13-2013		CTY RD K					
Well Constructor (Business Name) LARRY L JENKS						Lic. # 203		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.228 °N -89.16825 °W		Method Code GPS007					
Address JENKS WELL DRILLING WILD ROSE WI 54984-6700						Well Plan Approval #		SW SW Section Township Range or Govt Lot # 2 20 N 11 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? FAILING 2 IN.							
						Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 3.3		Construction Type Drilled									
3. Well serves 1 # of HOME						Hicap Well ? No											
Private, potable						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
5		Surface		94		No Rotary - Mud Circulation		No		T Q G -		Tan/Brown, Caving, Gravel/Cobbles/Boulders/Stones		Surface		21	
						No Rotary - Air		No		T Q Y -		Tan/Brown, Caving, Sand & Gravel		21		63	
						No Rotary - Air & Foam		No		T H C -		Tan/Brown, Hard/Firm, Clay		63		80	
						No Drill-Through Casing Hammer				T N S -		Tan/Brown, Fine, Sand		80		84	
						No Reverse Rotary				T W S -		Tan/Brown, Water Bearing, Sand		84		94	
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		37 ft. below ground surface		14 in. above grade					
5		IPSCO A53B T&C 15#/FT 1950 HYDRO				Surface		90		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 43 ft. below surface		Disinfected ? Yes					
5		12 SLOT JOHNSON SS				90		94		Pumping at 20 GP M for 1 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method												Filled & Sealed Well(s) as needed? Yes					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
				Surface													
13. Constructor / Supervisory Driller												Lic #		Date Signed			
LJ														10-04-2013			
Drill Rig Operator												Lic or Reg #		Date Signed			
CV														10-04-2013			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Building Overhang		6
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 11-21-2013

Updated On: 11-25-2013

Review Status: APPROVED