Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YJ366

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BARLOW, KENT	Phone #
Mailing Address: 2641 N 82ND ST	
City: WAUWATOSA	State: WI — Zip Code: 53213
County: Waushara	Co. Permit #: — Notification #: 49213501 — Completed: 09-13-2013
Well Constructor (Business Name): LARRY L JENKS	Lic. #: 203 — Facility ID # (Public Wells):
Address: JENKS WELL DRILLING, WILD ROSE WI 54984-6700	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3.3

1. Well Location

Town of SPRINGWATER			Fire # (if avail.): W5680
Street Address or Road Name and Number: CTY RD K			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.228 °N -89.16825 °W			Method Code: GPS007
SW SW or Govt Lot #	Section: 2	Township: 20 N	Range: 11 E

2. Well Type Replacement
of previous unique well # — constructed in
Reason for replaced or reconstructed well ? FAILING 2 IN.
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	94

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q G -	Tan/Brown, Caving, Gravel/Cobbles/Boulders/Stones	Surface	21
T Q Y -	Tan/Brown, Caving, Sand & Gravel	21	63
T H C -	Tan/Brown, Hard/Firm, Clay	63	80
T N S -	Tan/Brown, Fine, Sand	80	84
T W S -	Tan/Brown, Water Bearing, Sand	84	94

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	IPSCO A53B T&C 15#/FT 1950 HYDRO	Surface	90
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	12 SLOT JOHNSON SS	90	94

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
37 ft. below ground surface

10. Pump Test
Pumping level 43 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJ		10-04-2013
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CV		10-04-2013

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Building Overhang		6
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 11-21-2013 Updated On: 11-25-2013 Review Status: APPROVED