

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YK226		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BROOKS, BOB						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 3040 WYLDEFLOWER CT						Town of SPRINGWATER						N5866									
City OSHKOSH						State WI		Zip Code 54904				Street Address or Road Name and Number 24TH LANE									
County Waushara		Co. Permit #		Notification # 49445605		Completed 10-02-2013		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) LARRY L JENKS				Lic. # 203		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.19188 °N -89.12922 °W				Method Code GPS007							
Address JENKS WELL DRILLING WILD ROSE WI 54984-6700				Well Plan Approval #		NE SE		Section 24		Township 20 N		Range 11 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 10		2. Well Type New Well				of previous unique well # constructed in											
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?															
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
5		Surface		78		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						T Q S -		Tan/Brown, Caving, Sand		Surface		63			
												T N S -		Tan/Brown, Fine, Sand		63		70			
												T A S -		Tan/Brown, Coarse, Sand		70		78			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		38 ft. below ground surface				14 in. above grade							
5		IPSCO A53B T&C 15#/FT 1950 HYDRO				Surface		74		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 41 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ?											
5		15 SLOT JOHNSON SS				74		78													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
				Surface																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														LJ				10-25-2013			
														Drill Rig Operator		Lic or Reg #		Date Signed			
														CV				10-25-2013			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		18
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 11-21-2013

Updated On: 11-25-2013

Review Status: APPROVED