Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YK231

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BAUER, TED			Phone #
Mailing Address: W8473 STATE ROAD 21			
City: WAUTOMA	State: WI	Zip Code: 54982	
County: Waushara	Co. Permit #:	Notification #: 49554740	Completed: 10-18-2013

Well Constructor (Business Name): LARRY L JENKS	Lic. #: 203	Facility ID # (Public Wells):	
Address: JENKS WELL DRILLING WILD ROSE WI 54984-6700		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

1. Well Location

Town of DAKOTA				Fire # (if avail.): W8473
Street Address or Road Name and Number: STATE ROAD 21				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 44.0679 °N -89.30603 °W				Method Code: GPS007
NW NW or Govt Lot #	Section: 3	Township: 18 N	Range: 10 E	

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NON-COMPLY POINT IN BASEMENT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	46

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	N	S	-	Tan/Brown, Fine, Sand	Surface	14
T	A	S	-	Tan/Brown, Coarse, Sand	14	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	IPSCO A53B T&C 15#/FT 1950 HYDRO	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	15 SLOT JOHNSON SS	42	46

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

11 ft. below ground surface

10. Pump Test

Pumping level 11 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

JOHNS PLUMBING TO DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJ		11-01-2013
Drill Rig Operator	Lic or Reg #	Date Signed
CV		11-01-2013

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		20
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 11-21-2013 Updated On: 05-05-2020 Review Status: APPROVED