Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YM781

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BERG, THOMAS	Phone #: (715)559-3512
Mailing Address: 6697 US HWY 53	
City: EAU CLAIRE	State: WI Zip Code: 54701

County	Co. Permit #	Notification #	Completed
Eau Claire	33412	55859070	07-14-2015

Well Constructor (Business Name): KELLY OIUM WELL DRILLING INC	Lic. #: 8217
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: N50021 MISSELL ROAD STRUM WI 54770	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 4	

1. Well Location

Town of WASHINGTON	Fire # (if avail.): 6697
Street Address or Road Name and Number: US HWY 53	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD): 44.736 °N -91.3781 °W	Method Code: GCD013

SE NW or Govt Lot #	Section	Township	Range
	17	26 N	8 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: SHORT ON WATER

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	82

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	Top Soil	Surface	1
T	M	S	-	Brown, Medium, Sand	1	38
T	M	S	-	Brown, Medium, Sand w/Clay	38	78
T	A	S	-	Brown, Coarse, Sand	78	82

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.620 X A53B.280 EW TC	Surface	79
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	10 SLOT JOHNSON STAINLESS STEEL SCREEN	79	82

9. Static Water Level

58 ft. below ground surface

10. Pump Test

Pumping level 63 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY W/BENTONITE	Surface	6	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO		07-23-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BG		07-23-2015

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 08-03-2015 Updated On: 08-01-2019 Review Status: APPROVED