Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YM782

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: GUNDERSON, JOHN & KIM	Phone #: (715)456-7638
Mailing Address: 1443 BROOKLINE AVENUE	
City: EAU CLAIRE	State: WI — Zip Code: 54701

County	Co. Permit #	Notification #	Completed
Eau Claire	33420	55861428	07-15-2015

Well Constructor (Business Name): KELLY OIUM WELL DRILLING INC	Lic. #: 8217	Facility ID # (Public Wells):
Address: N50021 MISSELL ROAD STRUM WI 54770		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		4

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LINCOLN

Fire # (if avail.): S5464

Street Address or Road Name and Number: SUNRISE DRIVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NE SE or Govt Lot #	Section	Township	Range
	10	26 N	7 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
6	30	70

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	H	X	-	Brown, Firm, Sand & Clay	Surface	15
T	M	N	-	Brown, Medium, Sandstone	15	26
T	H	N	-	Brown, Hard , Sandstone	26	70

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.620 X A53B.280 EW TC	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method GROUT PUMP TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	30	14 S

9. Static Water Level
48 ft. below ground surface

10. Pump Test
Pumping level 53 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO		07-23-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BG		07-23-2015

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		77	Building Overhang		15
			Septic or Holding, or POWTS Tank		57

Comment:

Created On: 08-03-2015 Updated On: 08-03-2015 Review Status: APPROVED