Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YM783

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BARHYTE, BOB	Phone #: (715)456-7638
Mailing Address: N9293 US HWY 12/27	
City: MERRILLAN	State: WI — Zip Code: 54754
County: Jackson	Co. Permit #:
Notification #: 55901796	Completed: 07-20-2015
Well Constructor (Business Name): KELLY OIUM WELL DRILLING INC	Lic. #: 8217
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: N50021 MISSELL ROAD STRUM WI 54770	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.5	

1. Well Location

Town of ALMA	Fire # (if avail.): N9303
Street Address or Road Name and Number: US HWY 12/27	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4074 °N -90.8235 °W	Method Code: GCD013
SE SE or Govt Lot #	Section: 2 — Township: 22 N — Range: 4 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	5
6	5	33

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	S	-	Brown, Medium, Sand	Surface	32
T	H	N	-	Brown, Hard, Sandstone	32	33

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.620 X A53B.280 EW TC	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 22 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY W/BENTONITE	Surface	5	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO		07-23-2015
Drill Rig Operator	Lic or Reg #	Date Signed
BG		07-23-2015

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120

Type	Qualifier	Distance
Building Overhang		70
Septic or Holding, or POWTS Tank		178

Comment:

Created On: 08-03-2015 Updated On: 05-01-2020 Review Status: APPROVED