Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YM784

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: LUTES, NICK & ELIZABETH	Phone #: (715)926-5856
Mailing Address: W6372 ROCK CREEK ROAD	
City: MONDOVI	State: WI — Zip Code: 54755

County	Co. Permit #	Notification #	Completed
Eau Claire	33414	55909985	07-21-2015

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
KELLY OIUM WELL DRILLING INC	8217	

Address: N50021 MISSELL ROAD, STRUM WI 54770

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #:

Common Well #:

Specific Capacity: 2.2

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

1. Well Location

Town of DRAMMEN

Fire # (if avail.): W6372

Street Address or Road Name and Number: ROCK CREEK ROAD

Subdivision Name:

Lot #:

Block #:

Latitude / Longitude in Decimal Degree (DD): 44.6599 °N -91.6182 °W

Method Code: GCD013

NW SE or Govt Lot #	Section	Township	Range
	8	25 N	10 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	5
6	5	55

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	S	-	Brown, Medium, Sand	Surface	30
T	M	S	-	Brown, Medium, Sand w/Clay	30	33
T	H	N	-	Brown, Hard, Sandstone	33	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.620 X A53B.280 EW TC	Surface	35
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY W/BENTONITE	Surface	5	

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO		07-23-2015
Drill Rig Operator	Lic or Reg #	Date Signed
BG		07-23-2015

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 08-03-2015 Updated On: 08-01-2019 Review Status: APPROVED