

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YP098		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BERGER, JI						Phone # (715)874-6789		1. Well Location				Fire # (if avail.)			
Mailing Address N3681 420TH AVENUE						Town of DUNN						N3681			
City MENOMONIE						State WI		Zip Code 54751				Street Address or Road Name and Number 420TH AVENUE			
County Dunn		Co. Permit # 06231		Notification # 6483893801		Completed 06-25-2016		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) MICHAEL J WETTSTEIN				Lic. # 206		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.81403 °N -91.95683 °W				Method Code GPS006	
Address WETTSTEIN WELL DRILLING EAU CLAIRE WI 54702				Well Plan Approval #		NE NE		Section 21		Township 27 N		Range 13 W			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type Replacement				of previous unique well # constructed in					
Reason for replaced or reconstructed well ? NEED FOR WATER				Hicap Well ? No		Hicap Property ? No		Hicap Potable ?		Construction Type Drilled					
Private, potable				Heat Exchange ___ # of drillholes											
3. Well serves 1 # of HOME															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		140		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
T	S	S	-	Tan/Brown, Soft/Loose, Sand						Surface		43			
T	V	C	-	Tan/Brown, Non-Caving, Clay						43		50			
G	H	N	-	Gray, Hard/Firm, Sandstone						50		140			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
6		NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI IPSCO PIPE				Surface		50		30 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
										16 in. above grade					
7. Grout or Other Sealing Material										10. Pump Test					
Method										Developed ? Yes					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				Disinfected ? Yes					
		Surface								Capped ? Yes					
Filled & Sealed Well(s) as needed?										Yes					
12. Notified Owner of need to fill & seal ?															
13. Constructor / Supervisory Driller										Lic #		Date Signed			
MW															
Drill Rig Operator										Lic or Reg #		Date Signed			
JK															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Building Overhang		15
Building Drain - Sanitary		55	Sewer - Building Sanitary		65
			Septic or Holding, or POWTS Tank		90

Comment:

Created On: 07-19-2016

Updated On: 07-26-2016

Review Status: APPROVED