Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YP098

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BERGER, JI			Phone #: (715)874-6789
Mailing Address: N3681 420TH AVENUE			
City: MENOMONIE	State: WI	Zip Code: 54751	
County: Dunn	Co. Permit #: 06231	Notification #: 6483893801	Completed: 06-25-2016

1. Well Location

Fire # (if avail.): N3681

Town of DUNN

Street Address or Road Name and Number: 420TH AVENUE

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): MICHAEL J WETTSTEIN	Lic. #: 206	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 44.81403 °N -91.95683 °W
Address: WETTSTEIN WELL DRILLING, EAU CLAIRE WI 54702		Well Plan Approval #	Method Code: GPS006
		Approval Date (mm-dd-yyyy)	

NE	NE	Section	Township	Range
or Govt Lot #		21	27 N	13 W

2. Well Type Replacement

of previous unique well # | constructed in

Reason for replaced or reconstructed well ?: NEED FOR WATER

Construction Type: Drilled

3. Well serves 1 # of HOME	Hicap Well ? No	
Private,potable	Hicap Property ? No	
Heat Exchange____# of drillholes	Hicap Potable ?	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	140

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S	-	Tan/Brown, Soft/Loose, Sand	Surface	43
T	V	C	-	Tan/Brown, Non-Caving, Clay	43	50
G	H	N	-	Gray, Hard/Firm, Sandstone	50	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI IPSCO PIPE	Surface	50
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MW		
Drill Rig Operator	Lic or Reg #	Date Signed
JK		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120
Building Drain - Sanitary		55

Type	Qualifier	Distance
Building Overhang		15
Sewer - Building Sanitary		65
Septic or Holding, or POWTS Tank		90

Comment:

Created On: 07-19-2016 Updated On: 07-26-2016 Review Status: APPROVED