Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: YP099

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SYLTE, JON	Phone #: (715)563-4716
Mailing Address: E8623 180TH AVENUE	
City: MONDOVI	State: WI — Zip Code: 54755
County: Dunn	Co. Permit #: 06201 — Notification #: 6483083302 — Completed: 06-26-2016
Well Constructor (Business Name): MICHAEL J WETTSTEIN	Lic. #: 206 — Facility ID # (Public Wells):
Address: WETTSTEIN WELL DRILLING, EAU CLAIRE WI 54702	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.9

1. Well Location

Town of ROCK CREEK	Fire # (if avail.): E8623
Street Address or Road Name and Number: 180TH AVENUE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.74178 °N -91.71883 °W	Method Code: GPS006
SW SE or Govt Lot #:	Section: 9 — Township: 26 N — Range: 11 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	53
6	53	140

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 12depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S -	Tan/Brown, Soft/Loose, Sand	Surface	12
T H N -	Tan/Brown, Hard/Firm, Sandstone	12	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED AND CUPPLED 20 LBS PER ASTM A 53 B 1800 PSI IPSCO PIPE	Surface	53
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

55 ft. below ground surface

10. Pump Test

Pumping level 63 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method Tremie Pipe - Pumped

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement grout	Surface	53	18 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MW		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JK		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Drain - Sanitary		25

Type	Qualifier	Distance
Building Overhang		12
Sewer - Building Sanitary		35
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 07-19-2016 Updated On: 07-26-2016 Review Status: APPROVED