

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YP100		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner IRWIN, WADE						Phone # (715)874-6789		1. Well Location				Fire # (if avail.)							
Mailing Address 4977 174TH STREET						Town of LAFAYETTE						6638							
City CHIPPEWA FALLS						State WI		Zip Code 54729				Street Address or Road Name and Number 188TH STREET							
County Chippewa		Co. Permit # 0083		Notification # 6499819701		Completed 07-06-2016		Subdivision Name CSM 1699				Lot # 2		Block #					
Well Constructor (Business Name) MICHAEL J WETTSTEIN				Lic. # 206		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.93883 °N -91.29235 °W				Method Code GPS006					
Address WETTSTEIN WELL DRILLING EAU CLAIRE WI 54702				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 1 28 N 8 W				2. Well Type New Well									
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.7		Reason for replaced or reconstructed well ?				Construction Type Drilled									
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		45.5		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						T S S -		Tan/Brown, Soft/Loose, Sand		Surface		45.5	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		21 ft. below ground surface				28 in. above grade					
6		NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI IPSCO PIPE				Surface		42		10. Pump Test				Developed ? Yes					
										Pumping level 30 ft. below surface				Disinfected ? Yes					
										Pumping at 15 GP M for 2 Hrs.				Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?									
6		JOHNSON STAINLESS STEEL 10 SLOT				41.5		45.5											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?				Yes			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
				Surface															
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												MW						07-14-2016	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												JK						07-14-2016	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		8
Building Drain - Sanitary		40	Sewer - Building Sanitary		60
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 07-19-2016

Updated On: 07-26-2016

Review Status: APPROVED