Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YP100

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: IRWIN, WADE	Phone #: (715)874-6789
Mailing Address: 4977 174TH STREET	
City: CHIPPEWA FALLS	State: WI — Zip Code: 54729

County	Co. Permit #	Notification #	Completed
Chippewa	0083	6499819701	07-06-2016

Well Constructor (Business Name): MICHAEL J WETTSTEIN	Lic. #: 206
Address: WETTSTEIN WELL DRILLING, EAU CLAIRE WI 54702	
Facility ID # (Public Wells)	
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 1.7	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of LAFAYETTE

Fire # (if avail.): 6638

Street Address or Road Name and Number: 188TH STREET

Subdivision Name	Lot #	Block #
CSM 1699	2	

Latitude / Longitude in Decimal Degree (DD): 44.93883 °N -91.29235 °W
Method Code: GPS006

SW NE or Govt Lot #	Section	Township	Range
	1	28 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	45.5

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S -	Tan/Brown, Soft/Loose, Sand	Surface	45.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI IPSCO PIPE	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS STEEL 10 SLOT	41.5	45.5

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
28 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MW		07-14-2016
Drill Rig Operator	Lic or Reg #	Date Signed
JK		07-14-2016

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Drain - Sanitary		40

Type	Qualifier	Distance
Building Overhang		8
Sewer - Building Sanitary		60
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 07-19-2016 Updated On: 07-26-2016 Review Status: APPROVED