Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YP101

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MATHISON, JOHN	Phone #: (715)598-6601
Mailing Address: E9145 639TH AVENUE	
City: ELK MOUND	State: WI — Zip Code: 54739
County: Dunn	Co. Permit #: 07110 — Notification #: 6501155001 — Completed: 07-11-2016
Well Constructor (Business Name): MICHAEL J WETTSTEIN	Lic. #: 206 — Facility ID # (Public Wells):
Address: WETTSTEIN WELL DRILLING, EAU CLAIRE WI 54702	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.4

1. Well Location

Town of ELK MOUND	Fire # (if avail.): E8134
Street Address or Road Name and Number: CTY HWY E NORTH	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.92432 °N -91.75323 °W	Method Code: GPS006
SW NW or Govt Lot #:	Section: 8 — Township: 28 N — Range: 11 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	40
6	40	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 20depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S	-	Tan/Brown, Soft/Loose, Sand	Surface	20
T	H	N	-	Tan/Brown, Hard/Firm, Sandstone	20	80
G	H	N	-	Gray, Hard/Firm, Sandstone	80	90
T	H	N	-	Tan/Brown, Hard/Firm, Sandstone	90	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A53 B 1800 PSI IPSCO PIPE	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method Tremie Pipe - Pumped

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement grout	Surface	40	14 S

9. Static Water Level
37 ft. below ground surface

10. Pump Test
Pumping level 48 ft. below surface
Pumping at 15 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MW		07-14-2016
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JK		07-14-2016

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		220
Building Drain - Sanitary		65
Building Overhang		50
Sewer - Building Sanitary		70
Septic or Holding, or POWTS Tank		120

Comment:

Created On: 07-19-2016 Updated On: 07-26-2016 Review Status: APPROVED