

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YP101		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner MATHISON, JOHN						Phone # (715)598-6601		1. Well Location				Fire # (if avail.)									
Mailing Address E9145 639TH AVENUE						Town of ELK MOUND						E8134									
City ELK MOUND						State WI		Zip Code 54739				Street Address or Road Name and Number CTY HWY E NORTH									
County Dunn		Co. Permit # 07110		Notification # 6501155001		Completed 07-11-2016		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) MICHAEL J WETTSTEIN						Lic. # 206		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.92432 °N -91.75323 °W				Method Code GPS006					
Address WETTSTEIN WELL DRILLING EAU CLAIRE WI 54702						Well Plan Approval #		SW NW Section Township Range or Govt Lot # 8 28 N 11 W		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.4		Reason for replaced or reconstructed well ?				Construction Type Drilled									
3. Well serves 1 # of HOME						Hicap Well ? No		Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		40		No Rotary - Mud Circulation		No		T S S -		Tan/Brown, Soft/Loose, Sand		Surface		20					
6		40		120		No Rotary - Air		No		T H N -		Tan/Brown, Hard/Firm, Sandstone		20		80					
						Yes Rotary - Air & Foam		Yes		G H N -		Gray, Hard/Firm, Sandstone		80		90					
						No Drill-Through Casing Hammer				T H N -		Tan/Brown, Hard/Firm, Sandstone		90		120					
						No Reverse Rotary															
						No Cable-tool Bit ___ in. dia...		No													
						No Dual Rotary		No													
						Yes Temp. Outer Casing 10in. dia															
						Yes Removed? 20depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		37 ft. below ground surface				20 in. above grade							
6		NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A53 B 1800 PSI IPSCO PIPE				Surface		40		10. Pump Test				Developed ? Yes							
										Pumping level 48 ft. below surface				Disinfected ? Yes							
										Pumping at 15 GP M for 4 Hrs.				Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method Tremie Pipe - Pumped																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes							
Neat cement grout				Surface		40		14 S													
13. Constructor / Supervisory Driller								Lic #		Date Signed											
MW										07-14-2016											
Drill Rig Operator								Lic or Reg #		Date Signed											
JK										07-14-2016											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		220	Building Overhang		50
Building Drain - Sanitary		65	Sewer - Building Sanitary		70
			Septic or Holding, or POWTS Tank		120

Comment:

Created On: 07-19-2016

Updated On: 07-26-2016

Review Status: APPROVED