

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YP723		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner WEISSINGER, BRIAN C/O PORTSIDE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 810 S LANSING AVE								Town of BAILEYS HARBOR				7953							
City STURGEON BAY						State WI		Zip Code 54235				Street Address or Road Name and Number DEER CREST CT							
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #							
Door				57429056		01-07-2016						Block #							
Well Constructor (Business Name) CHARLIES PUMPS & WELL DRILLING INC				Lic. # 143		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.05787 °N -87.13095 °W				Method Code GPS008							
Address 1122 ROOSEVELT CT BRUSSELS WI 54204-9553				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 20 30 N 28 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9.87		Surface		9		Rotary - Mud Circulation				K - I -		BLACK ORGANIC TOPSOIL		Surface		2			
8		9		170		<u>Yes</u> Rotary - Air		<u>No</u>		I H L -		WHITE HF LIME		2		243			
6		170		243		Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? 9depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		70 ft. _____ ground surface				14 in. above grade					
6		WHEATLAND WR USA ASTM A-53/ASME SA53 6.625X.280 GR 21' 6 INCH SC				Surface		170		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ?					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 120 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method BRANDENHEAD												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT GROUT				Surface		170		48 S								01-02-2017			
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		27	Foundation Drain to Clearwater		8
Collector Sewer - San or Storm		180	Sewer - Building Sanitary		26

Comment:

Created On: 01-23-2017

Updated On: 12-03-2019

Review Status: