Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YP723

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WEISSINGER, BRIAN C/O PORTSIDE			Phone #
Mailing Address: 810 S LANSING AVE			
City: STURGEON BAY	State: WI	Zip Code: 54235	
County: Door	Co. Permit #:	Notification #: 57429056	Completed: 01-07-2016

1. Well Location

Fire # (if avail.): 7953

Town of BAILEYS HARBOR

Street Address or Road Name and Number: DEER CREST CT

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): CHARLIES PUMPS & WELL DRILLING INC	Lic. #: 143	Facility ID # (Public Wells)	
Address: 1122 ROOSEVELT CT BRUSSELS WI 54204-9553		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.2	

Latitude / Longitude in Decimal Degree (DD): 45.05787 °N -87.13095 °W

Method Code: GPS008

SW	SW	Section	Township	Range
or Govt Lot #		20	30 N	28 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9.87	Surface	9
8	9	170
6	170	243

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

Yes Rotary - Air ..... No

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

Yes Removed? 9depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K - I -	BLACK ORGANIC TOPSOIL	Surface	2
I H L -	WHITE HF LIME	2	243

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WR USA ASTM A-53/ASME SA53 6.625X.280 GR 21' 6 INCH SC	Surface	170
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

70 ft. _____ ground surface

10. Pump Test

Pumping level 120 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ?

7. Grout or Other Sealing Material

Method BRANDENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	170	48 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
		01-02-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		27	Foundation Drain to Clearwater		8
Collector Sewer - San or Storm		180	Sewer - Building Sanitary		26

Comment:

Created On: 01-23-2017 Updated On: 12-03-2019 Review Status: