

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YS295		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner TIMBER RIDGE DEVELOPMENT				Phone # (715)505-0782		1. Well Location				Fire # (if avail.)	
Mailing Address N5055 533RD STREET						Town of MENOMONIE				1115	
City MENOMONIE				State WI		Zip Code 54751				Street Address or Road Name and Number TIMBER PATH	
County Dunn		Co. Permit # 11181		Notification # 6686151501		Completed 12-27-2016		Subdivision Name TIMBER CANYON		Lot # 24	
Well Constructor (Business Name) KELLY OIUM				Lic. # 6244		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.8959 °N -91.9536 °W		Method Code GCD013	
Address OIUM WELL DRILLING & PUMP SERVICE STRUM WI 54770-0096				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 22 28 N 13 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 2		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?					
Private, potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
10		Surface		30		No Rotary - Mud Circulation		No		Geology Codes	
6		30		135		No Rotary - Air		No		Type, Caving/Noncaving, Color, Hardness, etc...	
						No Rotary - Air & Foam		No		From (ft.) To (ft.)	
						No Drill-Through Casing Hammer				T H C - Tan/Brown, Hard/Firm, Clay	
						No Reverse Rotary				T H N - Tan/Brown, Hard/Firm, Sandstone	
						Yes Cable-tool Bit 10in. dia...		No		G H N - Gray, Hard/Firm, Sandstone	
						No Dual Rotary		No		T H N - Tan/Brown, Hard/Firm, Sandstone	
						No Temp. Outer Casing ___ in. dia				G H N C Gray, Hard/Firm, Sandstone, Clayey	
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level	
6		6.620 X A53B.280 EW TC				Surface		34		10 ft. below ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is	
										24 in. above grade	
7. Grout or Other Sealing Material											
Method GROUT PUMP TREMIE PIPE											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test			
NEAT CEMENT GROUT		Surface		30		16 S		Pumping level 100 ft. below surface			
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed?											
13. Constructor / Supervisory Driller											
Lic #		Date Signed		KO				01-10-2017			
Drill Rig Operator		Lic or Reg #		BG				01-10-2017			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Building Overhang		88
			Septic or Holding, or POWTS Tank		98

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	01/11/2017	WATER SAMPLES WILL BE TAKEN WHEN WE HOOK UP.

Created On: 01-17-2017

Updated On: 06-09-2020

Review Status: APPROVED