

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YS296		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DUNGY, MARK & MICHELLE						Phone # (715)797-0163		1. Well Location				Fire # (if avail.)					
Mailing Address N15142 RIVER PINE DRIVE						Town of TREMPPEALEAU						N15142					
City TREMPPEALEAU						State WI		Zip Code 54661				Street Address or Road Name and Number RIVER PINE DRIVE					
County Trempealeau		Co. Permit # 0037		Notification # 6714811701		Completed 02-15-2017		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) KELLY OIUM				Lic. # 6244		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0569 °N -91.5025 °W				Method Code GCD013			
Address OIUM WELL DRILLING & PUMP SERVICE STRUM WI 54770-0096				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 7 18 N 9 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 4													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		6		No Rotary - Mud Circulation		No		T - S -		Tan/Brown, Sand		Surface		80	
6		6		121		No Rotary - Air		No		T - S M		Tan/Brown, Sand, Silty		80		100	
						No Rotary - Air & Foam		No		T A S -		Tan/Brown, Coarse, Sand		100		121	
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		75 ft. below ground surface				24 in. above grade			
6		6.620 X A53B.280 EW TC				Surface		118		10. Pump Test Pumping level 80 ft. below surface Pumping at 20 GP M for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
6		10 SLOT JOHNSON STAINLESS STEEL SCREEN				118		121									
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
DRILL SLURRY W/BENTONITE				Surface		5											
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												KO				02-27-2017	
												Drill Rig Operator		Lic or Reg #		Date Signed	
												BG				02-27-2017	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		15
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 03-20-2017

Updated On: 07-31-2019

Review Status: APPROVED