Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YS296

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner	Phone #
DUNGY, MARK & MICHELLE	(715)797-0163

Mailing Address: N15142 RIVER PINE DRIVE

City: TREMPEALEAU | State: WI | Zip Code: 54661

County	Co. Permit #	Notification #	Completed
Trempealeau	0037	6714811701	02-15-2017

Well Constructor (Business Name): KELLY OIUM | Lic. #: 6244 | Facility ID # (Public Wells)

Address: OIUM WELL DRILLING & PUMP SERVICE, STRUM WI 54770-0096

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 4

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

1. Well Location

Town of TREMPEALEAU | Fire # (if avail.): N15142

Street Address or Road Name and Number: RIVER PINE DRIVE

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 44.0569 °N -91.5025 °W | Method Code: GCD013

NE	NW	Section	Township	Range
or Govt Lot #		7	18 N	9 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	121

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	S	-	Tan/Brown, Sand	Surface	80
T	-	S	M	Tan/Brown, Sand, Silty	80	100
T	A	S	-	Tan/Brown, Coarse, Sand	100	121

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.620 X A53B.280 EW TC	Surface	118
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT JOHNSON STAINLESS STEEL SCREEN	118	121

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY W/BENTONITE	Surface	5	

9. Static Water Level

75 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO		02-27-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BG		02-27-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65

Type	Qualifier	Distance
Building Overhang		15
Septic or Holding, or POWTS Tank		30

Comment:

Created On: 03-20-2017 Updated On: 07-31-2019 Review Status: APPROVED