Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YS297

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: ZANNACKER, TODD	Phone #: (630)740-9234
Mailing Address: 13106 SUNDERLIN ROAD	
City: PLAINFELD	State: IL — Zip Code: 60585
County: Buffalo	Co. Permit #:
Notification #: 6716400901	Completed: 02-17-2017
Well Constructor (Business Name): KELLY OIUM	Lic. #: 6244
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: OIUM WELL DRILLING & PUMP SERVICE STRUM WI 54770-0096	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.4	

1. Well Location

Town of NAPLES	Fire # (if avail.): W133
Street Address or Road Name and Number: COUNTY ROAD HH	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.55132 °N -91.55728 °W	Method Code: GPS008

NE	NE	Section	Township	Range
or Govt Lot #		23	24 N	10 W

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of SHED
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	90

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	S	-	Tan/Brown, Sand	Surface	26
T	-	S	-	Tan/Brown, Sand w/Gravel	26	31
G	H	N	-	Gray, Hard/Firm, Sandstone	31	60
T	H	N	-	Tan/Brown, Hard/Firm, Sandstone	60	70
G	H	N	-	Gray, Hard/Firm, Sandstone	70	90

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.620 X A53B.280 EW TC	Surface	32
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 54 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO		02-27-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BG		02-27-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		24
			Septic or Holding, or POWTS Tank		50

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	03/16/2017	WATER TEST WELL BE TAKEN WHEN HOOKED UP.

Created On: 03-20-2017 Updated On: 05-01-2020 Review Status: APPROVED