Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YS298

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: NORDIE, MICHAEL	Phone #: (608)792-9241
Mailing Address: W13556 COUNTY ROAD C	
City: ETTRICK	State: WI — Zip Code: 54627
County: Jackson	Co. Permit #:
Notification #: 6738652501	Completed: 03-21-2017
Well Constructor (Business Name): KELLY OIUM	Lic. #: 6244
Facility ID # (Public Wells):	
Address: OIUM WELL DRILLING & PUMP SERVICE STRUM WI 54770-0096	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2	

1. Well Location

Town of ALBION	Fire # (if avail.): W13926
Street Address or Road Name and Number: COUNTY HIGHWAY C	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.2624 °N -91.01003 °W	Method Code: GPS008
SW SE or Govt Lot #:	Section: 29 — Township: 21 N — Range: 5 W

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: SANDPOINT
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	4
6	4	75

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	Y	-	Tan/Brown, Caving, Sand & Gravel	Surface	4
T	Q	S	-	Tan/Brown, Caving, Sand	4	40
T	Q	S	M	Dark Brown, Caving, Sand, Silty	40	45
T	Q	S	-	Tan/Brown, Caving, Sand	45	55
T	H	N	-	Tan/Brown, Hard/Firm, Sandstone	55	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.620 X A53B.280 EW TC	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO		03-22-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DJ		03-22-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		12
			Septic or Holding, or POWTS Tank		75

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	04/05/2017	WATER SAMPLE WILL BE TAKEN WHEN WE HOOK UP.

Created On: 04-10-2017 Updated On: 05-01-2020 Review Status: APPROVED