Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YT262

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: YADRO, JOHN	Phone #: (608)575-5570
Mailing Address: 5002 SUNRISE RIDGE TR	
City: MIDDLETON	State: WI — Zip Code: 53562
County: Vilas	Co. Permit #:
Notification #: 6883060001	Completed: 07-07-2017
Well Constructor (Business Name): BRADLEY M HARTMAN	Lic. #: 7084
Facility ID # (Public Wells):	
Address: HARTMAN WELL DRLG & PUMP, CONOVER WI 54519	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.3	

1. Well Location

Town of WASHINGTON	Fire # (if avail.): 1880
Street Address or Road Name and Number: MILITARY RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9378 °N -89.0768 °W	Method Code: GCD013
NW NE or Govt Lot #:	Section: 23 — Township: 40 N — Range: 11 E

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: pluged point
Construction Type: Drilled

3. Well serves 1 # of home
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	97

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	S	-	Caving, Sand	Surface	10
-	-	C	-	Clay	10	15
-	-	Y	-	Sand & Gravel	15	60
-	-	C	-	Clay	60	75
-	-	G	-	Gravel/Cobbles/Boulders/Stones	75	97

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Wheatland Steel Welded 0.280A53GRB	Surface	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method mounded

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
casing seal	Surface	20	0.75

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 40 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BH		07-17-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JZ		07-17-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Downspout/Yard Hydrant		75
Building Overhang		15	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 07-25-2017 Updated On: 06-30-2020 Review Status: APPROVED