

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YT264		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner NORTHERN BUILDERS (KIESLING)						Phone # (715)854-3064					
Mailing Address 4337 E STORMY LAKE RD											
City CONOVER				State WI		Zip Code 54519					
County Vilas		Co. Permit #		Notification # 6871904001		Completed 07-12-2017					
Well Constructor (Business Name) BRADLEY M HARTMAN						Lic. # 7084		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.0558 °N -89.3106 °W	
Address HARTMAN WELL DRLG & PUMP CONOVER WI 54519						Well Plan Approval #		SW SE Section Township Range or Govt Lot # 1 41 N 9 E		Method Code GCD013	
						Approval Date (mm-dd-yyyy)					
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves 1 # of home Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method						8. Geology					
Dia. (in.) 6		From (ft.) Surface		To (ft.) 62		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes	
						No Rotary - Mud Circulation		No		- Q S - Caving, Sand	
						No Rotary - Air		No		- - C - Clay	
						No Rotary - Air & Foam		No		G - S - Gray, Sand	
						Yes Drill-Through Casing Hammer				T - S - Tan/Brown, Sand	
						No Reverse Rotary				- - G - Gravel/Cobbles/Boulders/Stones	
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is	
Dia. (in.) 6		Material, Weight, Specification Wheatland Steel Welded 0.280A53GRB		From (ft.) Surface		To (ft.) 59		10 ft. below ground surface			
Dia. (in.) 6		Screen type, material & slot size 10 slot johnson stainless		From (ft.) 59		To (ft.) 62		10. Pump Test			
								Pumping level 25 ft. below surface			
								Pumping at 15 GP M for 2 Hrs.			
								Pumping Method ?			
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?					
Method mounded						Filled & Sealed Well(s) as needed?					
Kind of Sealing Material casing seal		From (ft.) Surface		To (ft.) 20							
						13. Constructor / Supervisory Driller BH					
						Lic #		Date Signed 07-12-2017			
						Drill Rig Operator JZ		Lic or Reg #		Date Signed 07-12-2017	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54	Building Overhang		20
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 07-25-2017

Updated On: 06-30-2020

Review Status: APPROVED