Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YT265

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVISON, RON			Phone #: (715)868-9745
Mailing Address: 5576 PEARL LAKE LN			
City: CONOVER	State: WI	Zip Code: 54519	
County: Vilas	Co. Permit #:	Notification #:	Completed: 07-14-2017

1. Well Location

Town of CONOVER

Fire # (if avail.): 5576

Street Address or Road Name and Number: PEAR LAKE LN

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
BRADLEY M HARTMAN	7084	

Latitude / Longitude in Decimal Degree (DD): 46.0536 °N -89.3114 °W

Method Code: GCD013

Address: HARTMAN WELL DRLG & PUMP, CONOVER WI 54519

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

NW or Govt Lot #	NE	Section	Township	Range
		12	41 N	9 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	S	-	CAVING, SAND	Surface	10
G	-	S	-	GRAY, SAND	10	45
T	-	S	-	TAN/BROWN, SAND	45	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND STEEL WELDED 0.280A53GRB	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT JOHNSON STAINLESS	57	60

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

10 in. below grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BH		07-14-2017
Drill Rig Operator	Lic or Reg #	Date Signed
JZ		07-14-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment: CASING IS BELOW GRADE IN SECTION 11. NO NOTIFICATION. NEVER GOT A RESPONSE FROM DRILLER.

Created On: 07-25-2017 Updated On: 06-30-2020 Review Status: APPROVED